



GATE VALVE DETAIL

N.T.S.

GENERAL NOTES

1. WRAP SOLID SLEEVE 6 MIL THICK POLYETHYLENE 2 FEET BEYOND FITTINGS.
2. THE VALVE BOX SHALL BE BACKFILLED SO THAT IT DOES NOT REST ON THE VALVE HOUSING. ALL BOLTS AND NUTS SHALL BE FLUOROCARBON COATED.

STANDARDS

1. AWWA C515  
MANUFACTURER
1. AMERICAN FLOW CONTROL

ISSUE DATE: SEPTEMBER 2018

TOWN & VILLAGE OF ELLICOTTVILLE

REVISIONS	DATE	COMMENTS
	1/8/2019	SCREW TYPE VALVE BOX - FLUOROCARBON COATING

EVL ENG DEPT.

WATER - W-08

