



TYPICAL SIDEWALK DETAIL  
N.T.S.

GENERAL NOTES

1. CONCRETE SHALL BE 3500 PSI AIR ENTRAINED CONCRETE, NYS DOT CLASS A - ITEM 501-2.
2. FULL DEPTH EXPANSION JOINTS SHALL BE SPACED EVERY 25 FT. CONTROL JOINTS SHALL BE SPACED EVERY 5 FT. WELDED WIRE FABRIC - W6XW6 SHALL BE USED IN ALL SIDEWALK APPLICATIONS AND SHALL BE PLACED 1-1/2" BELOW THE SURFACE.
3. SIDEWALK SHALL BE SEALED W/ A CHEMICAL SEALER FOLLOWING CONSTRUCTION.

STANDARDS

1. NYS DOT SPECIFICATIONS - AGGREGATE, CONCRETE
2. ADA REGULATIONS - RUNNING SLOPE & CROSS SLOPE

ISSUE DATE: SEPTEMBER 2018

TOWN & VILLAGE OF ELLICOTTVILLE

| REVISIONS | DATE | COMMENTS |
|-----------|------|----------|
|           |      |          |
|           |      |          |
|           |      |          |
|           |      |          |

EVL ENG DEPT.  
HIGHWAY - H-01

