



STORM SEWER TRENCH & PIPE DETAIL

N.T.S.

GENERAL NOTES

1. DETERMINATION OF STORMWATER CONVEYANCE PIPE TYPE AND SIZE SHALL BE MADE BY TOWN/VILLAGE ENGINEER.
2. HDPE PIPE SHALL BE SMOOTH INTERIOR, DUAL WALL, CORRUGATED – GASKETED JOINTS.
3. MINIMUM 18" OF COVER.

STANDARDS

1. AASHTO M294
2. ASTM F2306
3. ASTM C76
4. ASTM C507

MANUFACTURER

1. ADS – HDPE STORM PIPE

GEOTEXTILE FABRIC & DRAINAGE STONE MAY BE REQUIRED PRIOR TO GRANULAR BACKFILL

NYS DOT #1 WASHED STONE BEDDING TO BE INSTALLED PRIOR TO PIPE PLACEMENT

ISSUE DATE: SEPTEMBER 2018

TOWN & VILLAGE OF ELLICOTTVILLE

REVISIONS	DATE	COMMENTS

EVL ENG DEPT.

STORM -ST-02

